

CITY OF IOWA PARK, TEXAS

Annual Drinking Water Quality Report for Calendar Year 2021

Name of Water System: *City of Iowa Park*
Public Water System Identification #: *TX2430003*

The City of Iowa Park's public water system utilizes purchased surface water from the City of Wichita Falls, Texas (PWS# TX243001). Wichita Falls currently obtains their raw water from Lakes Kickapoo, Arrowhead, Kemp via Wichita River to lake and Secondary Terminal.

For additional information regarding this report, contact the Iowa Park City Hall at 940-592-2131.

Opportunities for public participation in decisions that may affect the quality of drinking water supplied by the City of Iowa Park are conducted on the second and fourth Monday of each month beginning at 7:00 p.m. at the Iowa Park City Council Chambers located at 103 North Wall Street. To learn more about future public meetings concerning your drinking water or to request to schedule an opportunity, please contact the City at 940-592-2131 or at www.iowapark.com.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs, springs and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include the following:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which come from a variety of sources such as agriculture, urban storm water runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The FDA establishes limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor or the color of drinking water, please contact the water system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immune-compromised persons such as those undergoing chemotherapy for cancer, persons who've undergone organ transplants, those who are undergoing treatment with steroids and people with HIV/AIDS or other immune system disorders can be particularly at risk for infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Iowa Park is responsible for providing high quality water but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty (30) seconds to two (2) minutes before using the water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize your exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:

<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW> .

| <u>SOURCE WATER NAME</u> | <u>TYPE OF WATER</u> | <u>REPORT STATUS</u> | <u>LOCATION</u> |
|----------------------------------|------------------------------|--------------------------|-------------------------------------|
| City of Wichita Falls | Surface Water | Active | Lake Arrowhead |
| | Surface Water | Active | Lake Kickapoo |
| | Surface Water | Active | Lake Kemp via Wichita River to Lake |
| | Surface Water | Active | Wichita Falls Secondary Terminal |

This report contains test result information on the quality of water provided by City of Wichita Falls, Texas (PWS: TX2430001) as well as test result information on the quality of water distributed by the City of Iowa Park.

2021 Consumer Confidence Report for Public Water System CITY OF IOWA PARK

This is your water quality report for January 1 to December 31, 2021 – CITY OF IOWA PARK provides Purchased Surface Water from City of Wichita Falls

Definitions and Abbreviations

Definitions and Abbreviations

The following tables contain scientific terms and measures, some of which may require explanation.

Action Level:

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picouries per liter (a measure of radioactivity)

ppb:

micrograms per liter or parts per billion

ppm:

milligrams per liter or parts per million

ppq

parts per quadrillion, or picograms per liter (pg/L)

ppt

parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

2021 Water Quality Test Results

| Disinfection By-Products | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------|-----------------|------------------------|-----------------------------|-----------------------|-----|-------|-----------|--|
| Halobacetic Acids (HAA5) | 2021 | 17 | 11.6 - 21 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection. |

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

| | | | | | | | | |
|------------------------------|------|----|-----------|-----------------------|----|-----|---|--|
| Total Trihalomethanes (TTHM) | 2021 | 26 | 21.3 - 35 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection. |
|------------------------------|------|----|-----------|-----------------------|----|-----|---|--|

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Individual Samples | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------------|-----------------|------------------------|-----------------------------|------|-----|-------|-----------|--|
| Nitrate [measured as Nitrogen] | 2021 | 0.052 | 0.052 - 0.052 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |

| Disinfectant Residual | Year | Average Level | Range of Levels Detected | MRDL | MRDLG | Unit of Measure | Violation (Y/N) | Source in Drinking Water |
|-----------------------|------|---------------|--------------------------|------|-------|-----------------|-----------------|--|
| Chloramines Total | 2021 | 3.394 | 2.1 - 4.0 | 4 | 4 | ppm | N | Water additive used to control microbes. |

| Inorganic Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------------|-----------------|------------------------|--------------------------|------|-----|-------|-----------|--|
| Aluminum | 2021 | 0.014 | 0.0065 - 0.014 | 0.2 | 0.2 | ppm | N | Natural Geology; Rock and soil erosion. |
| Barium | 2021 | 0.042 | 0.036 - 0.042 | 2 | 2 | ppm | N | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Fluoride | 2021 | 0.729 | 0.674 - 0.729 | 4 | 4.0 | ppm | N | Erosion of natural deposits; Water additive which promotes strong leach; Discharge from fertilizer and aluminum factories. |
| Nitrate [measured as Nitrogen] | 2021 | 0.096 | 0.074 - 0.096 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Nitrite [measured as Nitrogen] | 2015 | 0.07 | 0 - 0.065 | 1 | 1 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |

| Radioactive Contaminants | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation | Likely Source of Contamination |
|--------------------------|-----------------|------------------------|--------------------------|------|-----|--------|-----------|---|
| Beta/photon emitters | 2021 | 9.5 | 9.5 | 0 | 50 | pCi/L* | N | Decay of natural and man-made deposits. |

*EPA considers 50 pCi/L to be the level of concern for beta particles.

| | | | | | | | | |
|-------------------------|------------|---|-------|---|---|-------|---|------------------------------|
| Combined Radium 226/228 | 06/21/2011 | 1 | 1 - 1 | 0 | 5 | pCi/L | N | Erosion of natural deposits. |
|-------------------------|------------|---|-------|---|---|-------|---|------------------------------|

Turbidity

| | Limit (Treatment Technique) | Level Detected | Violation | Likely Source of Contamination |
|--------------------------------|-----------------------------|----------------|-----------|--------------------------------|
| Highest single measurement | 1 NTU | 0.95 NTU | N | Soil runoff. |
| Lowest monthly % meeting limit | 0.3 NTU | 96% | N | Soil runoff. |

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration

Coliform Bacteria

| Maximum contaminant Level Goal | Total Coliform Maximum Contaminant Level | Highest No. of Positive | Fecal Coliform or E. Coli Maximum Contaminant Level | Total No. of Positive E. Coli or Fecal Coliform Samples | Violation (Y/N) | Likely Source of Contamination |
|--------------------------------|--|-------------------------|---|---|-----------------|--------------------------------------|
| 0 | 5 | 0 | 1 | 0 | N | Naturally present in the environment |

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90th Percentile | # Sites Over AL | Units | Violation | Likely Source of Contamination |
|-----------------|--------------|------|-------------------|-----------------|-----------------|-------|-----------|--|
| Copper | 07/17/2019 | 1.3 | 1.3 | 0.0243 | 0 | ppm | N | Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems |
| Lead | 07/17/2019 | 0 | 15 | 1.7 | 0 | ppb | N | Corrosion of household plumbing systems; Erosion of natural deposits. |